

Project name	Milton Hill, Clapham		
Design note title	Flood Risk and Drainage - Non-Technical Summary		
Document reference	16254		
Author	Jon Cracknell, Senior Flood Risk Consultant		
Revision	P01		
Date	8 February 2021	Approved	✓

The development site has been identified to be at low/negligible risk of flooding from all potential sources.

The means of surface water drainage for the development site will comprise either:

- i. A traditional piped sewer network which will convey surface water run-off from the entire site via gravity to a new attenuation basin, which will be located in the southern part of the site. From there surface water run-off will infiltrate into the ground; or.
- ii. Should infiltration be found to not be viable, an alternative strategy will be to attenuate flows in a new attenuation basin before discharging, at a restricted rate, to the nearby Anglian Water public sewer system.

Foul water from the development site will be managed via a traditional piped sewer network which will convey foul water flows to an existing Anglian Water public foul water sewer located within Loak Close.